

Drinking Water Quality and Compliance Town of Kelvington- Annual Notice to Consumers

Introduction

Water Security Agency requires that at least once each year waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a Minister's Order or Permit to Operate a waterworks. The following is a summary of the **Town of Kelvington's** water quality and sample submission compliance record for the year from **January 1, 2021 to December 31, 2021**. This report was completed on the **13th of June, 2022**. Readers should refer to SE's "Municipal Drinking Water Quality Monitoring Guidelines, November 2002, EPB 202" for more information on minimum sample submission requirements and the meaning of type of sample. Permit requirements for a specific waterworks may require more sampling than outlined in the department's monitoring guidelines. If consumers need more information on the nature and significance of specific water tests, for example, "what is the significance of Selenium in a water supply", more detailed information is available from: <http://www.he-sc.gc.ca/hecs-sesc/water/dwgsup.htm>. and <http://www.saskh2o.ca>

Water Quality Standards

Bacteriological Quality

Parameter/ Location	Limit	Regular Samples Required	Regular Samples Submitted	# of Positive Regular Submitted (%)
Town of Kelvington				
Total Coliform and Background Bacteria	0 Organisms/100 mL Less than 200/100 mL	52	52	0

Water Disinfection –

Chlorine Residual in Distribution System for Test Results Submitted with Bacteriological Samples

Parameter	Minimum Limit	Total Chlorine Residual Range	Free Chlorine Residual Range	# Tests Required	# Tests Submitted	# Adequate Chlorine (%)
Town of Kelvington						
Chlorine Residual	0.1 mg/L free OR 0.5 mg/L total	1.17-1.42	1.06-1.31	52	52	100%

Water Disinfection - Free Chlorine Residual for Water Entering Distribution System from Waterworks Records-From Water Treatment Plant Records

	Limit (mg/L)	Test Level Range	# Tests Performed	# Tests Not Meeting Requirements
Town of Kelvington				
Free Chlorine Residual	at least 0.1	1.01-1.37	365	0

High Ammonia levels affect Free Chlorine Levels. SE is aware of this levels and quality is still good.

A minimum of 0.1 milligrams per litre (mg/L) free chlorine residual is required for water entering the distribution system. Tests are normally performed on a daily basis by the waterworks operator and are to be recorded in operation records. This data includes the number of free chlorine residual tests performed, the overall range of free chlorine residual (highest and lowest recorded values) and the number of tests and percentage of results not meeting the minimum requirement of 0.1 mg/L free chlorine residual.

Turbidity – From Water Treatment Plant Records

Parameter	Limit (NTU)	Test Level Range	# Tests Not Meeting Requirements	Maximum Turbidity (NTU)	# Tests Required	# Tests Performed
Turbidity	1.0NTU	.06-.32	0	0.05-.14	365	365

Chemical – Health Category

All waterworks serving less than 5000 persons are required to submit water samples for SE's Chemical Health category once every **2 years**. The Chemical Health category includes analysis for arsenic, barium, boron, cadmium, chromium, fluoride, lead, nitrate, selenium and uranium.

The last sample for **Chemical Health** analysis was submitted on **June 17, 2020**

Sample results indicated that the provincial drinking water quality standards were not exceeded.

Limit Parameter	Limit MA	Sample IMAC (mg/L)	# Samples Result(s)	Samples Exceeding Limit	
Arsenic	<25 ug/L	1	6.4 ug/l	NONE	* Results expressed as average values for communities or waterworks that fluoridate drinking water supplies or those with elevated concentrations of fluoride or nitrates.
Barium	<1000 ug/L	1	<0.0005	NONE	
Boron	<5 mg/L	1	0.27 mg/l	NONE	
Cadmium	<5 ug/L	1	<0.01 ug/L	NONE	
Chromium	<50 ug/L	1	<0.0005 mg/l	NONE	
Fluoride (avg*)	<1.5 mg/L	1	<0.01 mg/l	NONE	
Lead	< 100ug/L	1	<0.001 mg/l	NONE	
Nitrate (avg.*)	<45 mg/L	1	<0.04 mg/l	NONE	
Selenium	<10 ug/L	1	<0.0001 mg/l	NONE	
Uranium	<20 ug/L	1	<0.1 ug/l	NONE	

General Chemical

Parameter	Aesthetic Objectives * (mg/L)	Sample Results (Average)	# Samples Required	# Samples Submitted
Alkalinity	< 500 mg/L	93 mg/l	1	1
Bicarbonate	No Objective	113 mg/l	1	1
Calcium	No Objective	0.2 mg/l	1	1
Carbonate	No Objective	<1 mg/l	1	1
Chloride	< 250 mg/L	1.4 mg/l	1	1
Conductivity	No Objective	171 uS/cm	1	1
Hardness	< 800 mg/L	<1 mg/l	1	1
Magnesium	< 200 mg/L	0.0012 mg/l	1	1
PH	No Objective	7.97 pH units	1	1
Sodium	<300 mg/L	43mg/l	1	1
Sulphate	< 500 mg/L	1.7 mg/l	1	1
Total dissolved Solids	< 1500 mg/L	108 mg/l	1	1

All waterworks serving less than 5000 persons are required to submit water samples for SE's General Chemical category once **every two years** if a ground water source and once per three months every second year if a surface water or blended surface/groundwater source. The General Chemical category includes analysis for alkalinity, bicarbonate, calcium, carbonate, chloride, conductivity, hardness (as CaCO₃), magnesium, sodium, sulphate and total dissolved solids.

The last sample for **General Chemical** analysis was required in **2020** and submitted on **June 17, 2020**. *Sample results indicated that there were no exceedances of the provincial aesthetic objectives for the General Chemical category.*

*Objectives apply to certain characteristics of or substances found in water for human consumptive or hygienic use. The presence of these substances will affect the acceptance of water by consumers and/or interfere with the practice of supplying good quality water. Compliance with drinking water aesthetic objectives is not mandatory as these objectives are in the range where they do not constitute a health hazards. The aesthetic objectives for several parameters (including hardness as CaCO₃, magnesium, sodium and total dissolved solids) consider regional differences in drinking water sources and quality.

More information on water quality and sample submission performance may be obtained from:

Town of Kelvington, Box 10 Kelvington, Saskatchewan S0A 1W0 kelvington@sasktel.net 306-327-4482